



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110034, Building Permit - Commercial
Address: 1221 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Passed	Monday, April 04, 2011
Above Ceiling Inspection	John Borns	Passed	Monday, April 04, 2011
Occupancy Inspection - Codes Commercial	John Borns	Not Ready	Monday, April 04, 2011
Occupancy Inspection - Fire	Joe Dir	Not Ready	Monday, April 04, 2011

Corrective Action Required
1 MISC

(1) INSTALL THE MISSING EXIT/COMBO EMERGENCY LIGHTING ABOVE THE ENRT DOOR.
(2) MOUNT (1) FIRE EXTINGUISHER MINIMUM SIZE OF 2A-10BC CLOSE TO AN EXIT WITH THE TOP OF THE EXTINGUISHER NO HIGHER THAN 60' OFF THE FLOOR.

Comments: