

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215970
Address: 4544 NE SENECA TER, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Adam Nacke	Failed	Monday, August 29, 2022

Corrective Action Required:

1	Miscellaneous Correction	8-29-22 AN. Form are in place but there is not 4" of aggregate for the base it 50% dirt
---	--------------------------	---

Comments: