

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220521
Address: 3216 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Monday, August 29, 2022

Corrective Action Required:

1	Misc	-missing stud pack garage w wall see bath 4 (3) 2x4 under triple 2x10 -fireblock dead space to ceiling space at garage entry seal penetrations for wires -ufer ground rod connection to remain accessible
---	------	---

Okay to insulate do not cover any items in need of inspection

Comments: