

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20211958  
Address: 2020 SW HOOK RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Sediment Control (ESC) Inspection</b>	Ryan Heckman	Failed	Monday, August 29, 2022

Informational:

1	Misc	Erosion Control Failed
Corrective Action Required:		
2	Misc	7.26.2022 Replace all gutter buddies
Corrective Action Required:		
3	Misc	8.8.2022 Replace all inlet protection devices.

8-29-22 RH. Storm Inlets need to be cleaned out. Some are starting to grow vegetation out of them.

**Comments:**