

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220646
Address: 805 NE LAKEWOOD BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Failed	Monday, August 29, 2022

Corrective Action Required:

1	Misc	-At rear, complete in-wall DVW and protect DVW where within 1.25" of bottom wall track surface
---	------	--

****OK TO ROCK THE FRONT COUNTER HALF WALLS AND OFFICE/STORAGE WALLS ONLY**

Comments: