

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20213814
Address: 3821 SW MARYVILLE PL, LEES SUMMIT, MO 64082
Inspected On: Monday, August 29, 2022
Inspected By: Shawn Hoffman
Expiration Date: 9/28/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Temporary C of O	Monday, August 29, 2022

Corrective Action Required:

1	Miscellaneous Correction	pay all fees Sidewalk and driveway inspection pending As graded plot plan required Provide Splash blocks Sump discharge minimum of 36" from foundation Bottom riser step from deck over 7 3/4" to landing Provide clearance siding to grade back of house
---	-----------------------------	---