

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20214607

Address: 902 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081904 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081906 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081908 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081910 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081900 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection</b>	Ronald Paynter	Passed	Monday, August 29, 2022

Informational:

1 Misc

Sewer tie in completed 8/26/22, this tie in runs into the back of a 6"x4" wye via a 6" to 4" reducer. The service line for the building north of it(914 Black Twig) runs into the top of the 4" wye connection and they run into a 6" service line to the main into an 8"x6" wye. Spoke with Brent Dye at water and Amanda Bagwell agreed this was acceptable, and they would not need to remove the existing wye connection for this building. 8/26/22 ES

**Comments:**