

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220897

Address: 1002 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811004 NW BLACK TWIG CIR, LEES SUMMIT, MO
640811006 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811008 NW BLACK TWIG CIR,
LEES SUMMIT, MO 640811000 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection	Eric Sharp	Partial	Monday, August 29, 2022

Informational:

1 Misc

Miller plumbing was working on sanitary service on NW side of building.
8/29/22 ES

Comments: