

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214609

Address: 934 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081936 NW BLACK TWIG CIR, LEES SUMMIT, MO
64081938 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081932 NW BLACK TWIG CIR, LEES
SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection	Ronald Paynter	Passed	Monday, August 29, 2022

Informational:

1 Misc

Miller Plumbing installed sanitary connection on north side of building using 4" SDR26 26 pipe into a 6" wye with use of expander at wye connection on main. 8/29/22 ES

Comments: