

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20214608

Address: 916 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081918 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081920 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081922 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081924 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081926 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081928 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081914 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection</b>	Ronald Paynter	Passed	Monday, August 29, 2022

Informational:

1 Misc

Sewer tie in for south side of building completed 8/26/22, this tie in runs into the top of a 6"x4" wye. The service line for the building south of it(900-910 Black Twig) runs into the back of the 6" wye connection and they run into a 6" service line to the main into an 8"x6" wye all pipe and fittings were SDR26. Spoke with Brent Dye at water and Amanda Bagwell agreed this was acceptable, and they would not need to remove the existing wye connection for this building. 8/26/22 ES

Sewer tie in for north side of building completed using 4" SDR26 pipe into a 6" wye using an expansion fitting. 8/26/22 ES

**Comments:**