CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20215181Address:2034 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Passed	Tuesday, August 30, 2022
Corrective Action Required:			
1 Misc	-missing nuts on anchors in garage (could not inspect) -install all windows and doors -complete stairs at garage and fire block -complete bath fans at master -complete bath fan in jack and Jill bath		

Comments: