

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214078
Address: 1513 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Tuesday, August 30, 2022

Corrective Action Required:

1	Misc	-Sidewalk and Driveway inspections pending -Pay all outstanding fees -Address basement stair risers greater than 7.75" -Label non GFCI receptacle at panel -Provide 1" clearance to electrical conduit at furnace b vent -Foundation drainage to extend 36" -Seal patch in siding at west receptacle -Seal exterior penetrations and top of meter can at east
---	------	--

Comments: