CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20215181Address:2034 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, August 30, 2022
Corrective Action Required:			
1 Misc	 -address pending driveway inspection -address broken up back patio -pay all fees -obtain lawn irrigation permit -address to be properly illuminated -security screws at garage rear door -stairs at back patio to code -water anti syphon device with set screw sheered off -lock out for hot water heater -splash block and sump pump discharge to extend 36" from foundation -check water meter at time of sod -check siding from grade at time of sod 		

Comments: