CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20215945

Misc

Address: 2101 SE HAMBLEN RD, LEES SUMMIT, MO 640822620 SE RANSON RD, LEES SUMMIT, MO

640821971 SE HAMBLEN RD, LEES SUMMIT, MO 640821240 SE HOOK LN, LEES SUMMIT,

On Monday 8-29-2022. Redford resumed Sanitary Install. and place MH 54-21

MO 640821745 SE HAMBLEN RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:			
Sanitary Sewer Construction Inspection		Tom Taylor	Partial	Tuesday, August 30, 2022			
Informational:							
1	Misc	7-13-22 RH. Interceptor portion of project is down due to pipe mender missing a part. MH-14 was damaged while test pit was being dug. Contractor knew and was going to replace.					
Informational:							
2	Misc	On Thursday day the contractor resumed Sanitary Sewer installation. Contractor installed approx. 120 LF of 30" plastic pipe and back filled pipe.					
Informational:							
3	Misc	On Friday, 8-13-2022 Redford Excavating placed approx 100LF of 30" Pipe and backfilled pipe.					
Informational:							
4	Misc	sewer interceptor movem	reek. On Thursday, 8-18-202 nent to next man hole. Suppose her Tuesday or Wednesc	olied wrong Man Hole			
Informati	onal:	due to a wrong made stru	ord could not move forward cture. Contractor moved base graded throughout project	ck to water crossings			
miomati	Oliul.						

and installed 8	3" drop for exi	sting sewer c	onnection.	Contractor	placed a	approx
100 LF of 24" p	lastic sewer p	pipe and comp	oacted.			

Comments: