



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110060, Building Permit - Commercial
Address: 970 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Commercial	John Borns	Passed	Wednesday, April 06, 2011
Gas Piping Inspection - Commercial	John Borns	Passed	Wednesday, April 06, 2011

**Comments: GAS PRESSURE TEST HELD STEADY AT > 10 PSI FOR > 10 MINUTES.
RELEASE SERVICE. ROOFTOP GAS PIPING MUST BE PAINTED OR OTHERWISE
PROTECTED BEFORE FINAL INSPECTION.**