

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220897

Address: 1002 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811004 NW BLACK TWIG CIR, LEES SUMMIT, MO  
640811006 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811008 NW BLACK TWIG CIR,  
LEES SUMMIT, MO 640811000 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Service Inspection</b>	Eric Sharp	Passed	Tuesday, August 30, 2022

Informational:

1	Misc	Water service connections made 6/3/22 ES
---	------	--

**Comments:**