CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210875

Address: 3057 NW THOREAU LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Shawn Hoffman Failed Tuesday, August 30,

Residential 2022

Corrective Action Required:

1 Misc • final grading and sod

• Pay all fees

• Complete hardware on sliding door

* Prrovide gaurd rail or adjest grade front stoop over 30"

Comments: