CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213070

Address: 4817 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Khanh Nguyen Failed Tuesday, August 30,

Residential 2022

Corrective Action Required:

1 Misc **Clean mud off sidewalk and the street

- -Obtain lawn irrigation permit and submit backflow valve test report to city
- -As-graded plot plan is required
- -Final grade, sod, downspout and sump pump extension.
- -Secure protect exposed NM wiring and secure within 8" of kitchen hood receptacle box
- -Fasten the exterior doors strike plates to studs with 3" screws
- -Provide min one receptacle for each separate unfinished portion of basement
- $\ensuremath{^{**}}\xspace$ need one available receptacle in the room with the furnace and water

heaters

Comments: