

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220896

Address: 1071 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811073 NW BLACK TWIG CIR, LEES SUMMIT, MO  
640811075 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811069 NW BLACK TWIG CIR,  
LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Service Inspection</b>	Eric Sharp	Passed	Wednesday, August 31, 2022

Informational:

1 Misc

ESS replaced copper out of meter pits to a minimum of 10' copper out of back of meter and then tied into poly pipe running into house. 8/26/22 ES

**Comments:**