

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20215274

Address: 3695 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643695 NE AKIN DR, Unit:C, LEES SUMMIT, MO  
640643695 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643695 NE AKIN DR, Unit:A, LEES  
SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Commercial</b>	Khanh Nguyen	Failed	Wednesday, August 31, 2022

Corrective Action Required:

1	Misc	-Gas piping test pressure less than ten psi
---	------	---

**Comments:**