

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210263

Address: 1801 NW OBRIEN RD, LEES SUMMIT, MO 64081 520 NW HOPE LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Wednesday, August 31, 2022

Corrective Action Required:

1 Misc

BUILDING A HARD LIDS:

5001-PROVIDE ACCESS PANEL FOR J BOXES

5007-SECURE MC, COMPLETE ELECTRICAL

4001-OK

4007-COMPLETE MECHANICAL, PROVIDE ACCESS PANELS FOR J BOXES AND DAMPERS, COMPLETE SPRINKLER DROPS, SECURE MC

3001-OK

3007- PROVIDE ACCESS PANELS FOR J BOXES AND DAMPERS, COMPLETE SPRINKLER DROPS, SECURE MC

2001-PROVIDE ACCESS PANELS FOR J BOXES AND DAMPERS, SECURE MC

2007-PROVIDE ACCESS PANELS FOR J BOXES AND DAMPERS

Comments: