

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220891

Address: 1014 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081
1016 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081
1018 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081
1012 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection	Eric Sharp	Passed	Wednesday, August 31, 2022

Informational:

1 Misc

Miller Plumbing installed sewer connection using SDR26 4" pipe and fittings going into 6" connection to 6" wye on main. 8/31/22 ES

Comments: