

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215573
Address: 421 NW KAYLEA CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Thursday, September 01, 2022

Corrective Action Required:

1	Miscellaneous Correction	Sidewalk inspection pending Provide final grade & sod Provide splash blocks Provide address Complete backsplash & provide cover plates kitchen counter Garage door shall be self closing & self latching Provide cap DWV garage sink Provide (2) 3" screws in each exterior door hinge & strike plate Sump shall discharge 36" from foundation Find Manhole cover near ADA ramp
---	--------------------------	--

Comments: