

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215503
Address: 142 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Thursday, September 01, 2022

Corrective Action Required:

1	Miscellaneous Correction	No deck pier inspection on record As graded Plot plan is required prior to sodding Seal top of exterior light fixtures Provide two 3" screws in each exterior door hinge & strike plate Provide splash blocks Seal top of meter can & ac disconnect Nail joist hanger stair landing Sump shall discharge 36" from foundation Raise grade at sump discharge to prevent standing water Provide gravel base in water meter pit
---	--------------------------	--

Comments: