

DEVELOPMENT SERVICES

Residential Plan Review

September 01, 2022

NEW MARK HOMES - KC LLC
5207 NW CROOKED ROAD
PARKVILLE, MO 64152
(816) 969-9010

Permit No: PRRES20224220
Plan Name:
Project Address: 2055 NW OBRIEN RD, LEES SUMMIT, MO 64081
Parcel Number: 262466
Location: WOODSIDE RIDGE 2ND PLAT LOTS 144 THRU 198 INCLUSIVE AND TRACTS I, J AND K --- LOT 183
Type of Work: NEW SINGLE FAMILY
Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY
Description: NEW HOUSE - FINISHED BASEMENT - COVERED DECK

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide two (2) copies of any revised sheets and/or additional information.

Development Services Department (816) 969-1200

Residential Plan Review

Reviewed By: Kim Brennan

Approved

1. Designate locations of smoke detectors and carbon monoxide detectors. (IRC Section R314 and R315)

Not shown for bedroom #7

2. Provide combustion air calculations and specify transfer air grilles for fuel burning appliances located in confined space(s). (IRC Chapter 17 and Section G2407)

3. Provide details for any walls over 10 feet in height. Include stud grade, size, spacing and actual, uninterrupted height. (IRC Section 602.3.1 and Table 602.3(5) & 602.3.1)

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:	
Residential, Decks	204
Residential, Finished basements	1893
Residential, garage	636

Residential, Living Area (Not Finished Basement)		2358	
Residential, Un-Finished basements		358	
Roofing Material		Number of Bathrooms	5
Number of Bedrooms	7	Number of Stories	1
Number of Living Units	1	Total Living Area	4251