

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213681
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Robb Popp	Failed	Thursday, September 01, 2022

Corrective Action Required:

1	Misc	-Connect grounding electrode system to neutral -Connect water service pipe to grounding electrode system -Provide (2) 5/8" ground rods 6' apart -Provide address at disconnect and meters
---	------	--

Comments: