

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213681
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Thursday, September 01, 2022

Corrective Action Required:

1 FIRST FLOOR

THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS

AREA C

UNITS AND CORRIDORS APPROVED EXCEPT AS NOTED

-Correct penetrations in shaft wall

AREA B -COMPLETE

Corrective Action Required:

2 SECOND FLOOR

THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS

AREA "B" UNITS AND CORRIDORS

AREA "C" UNITS AND CORRIDORS

Corrective Action Required:

3 THIRD FLOOR

THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS

AREA "B" UNITS AND CORRIDORS

AREA "C" UNITS AND CORRIDORS

Corrective Action Required:

4	STAIR TOWER 1	STAIR TOWER "A"
		-OK

Corrective Action Required:

5	STAIR TOWER 2	STAIR TOWER "B"
---	---------------	-----------------

Corrective Action Required:

6	STAIR TOWER 3	STAIR TOWER "C"
---	---------------	-----------------

Comments: