

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211432
Address: 3105 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, September 01, 2022

Corrective Action Required:

1	Misc	TCO until - 4/11/22 -submit tco extension request -All exterior items still need to be checked -tamper caps at A/c unit -splash blocks and sump pump discharge to extend 36" from foundation -pay all fees before final C/o
---	------	--

Comments: