

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220646  
Address: 805 NE LAKEWOOD BLVD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Hood/Duct Inspection</b>	Khanh Nguyen	Failed	Thursday, September 01, 2022

Corrective Action Required:

1	Misc	**NOT READY FOR INSPECTION. PROVIDE PLAN FOR THE KITCHEN HOOD SYSTEM -COMPLETE GREASE DUCT AND PROVIDE LIGHT TEST WITH MIN 100 W LIGHT BULB
---	------	--

**Comments:**