

# LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS  
207 SE DOUGLAS STREET  
LEE'S SUMMIT, MISSOURI 64063-2372  
(816) 969-1300  
FAX (816) 969-1313  
TDD (816) 969-7407

## PLANS REVIEW CONDITIONS

Permit No:	PRCOM20110411	Date:	April 07, 2011
Project Title:	New View Interiors	Applicant:	JAYHAWK FIRE SPRINKLERS
Location:	400 SW LONGVIEW BLVD, Unit:109, LEES SUMMIT, MO 64081		10629 SUMMIT STREET
Type of Work:			LENEXA , KS 66215
Occupancy Group:	M		(913)422-3770
Description:	Tenant Finish for New View Interiors		
Construction Type:	Type VB (Unprotected)		
Map Page:	194E		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

### **Sprinkler Plan Review**

**Reviewed By: Jim Eden**

**Released for Construction**

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Plans received April 6, 2011.

2. 2006 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

The existing system shall have documentation of a current annual inspection.

3. Coverage of the existing sprinkler system to be confirmed at inspection.