

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220630
Address: 1249 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, September 02, 2022

Corrective Action Required:

1	Misc	-Seal gap at wall top plates (return air space at stair/bathroom wall)**Look inside the return air space at bathroom sink. There are gaps at wall top plates that are open to the roof space. Seal these gaps from roof space
---	------	---

Comments: