

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215066

Address: 2102 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822104 SW HOLDBROOKS DR, LEES SUMMIT,
MO 640822106 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822108 SW
HOLDBROOKS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, September 02, 2022

Corrective Action Required:

1 Misc

UNIT 2102:

-provide stud shoe at stud garage north wall bored for DWV (nail off stud shoes)

-protect service panel from pex water lines above

UNIT 2104:

Ok

UNIT 2106:

Ok

UNIT 2108:

-protect service panel from pex water lines above

Comments: