

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214080

Address: 2005 SW OSAGE DR, LEES SUMMIT, MO 640822003 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, September 02, 2022

Corrective Action Required:

1 Misc

- submit as graded plot plan
- obtain lawn irrigation permits
- seal all exterior penetrations
- 2003
- GFCI protection for all kitchen outlets see island
- open junction box at basement stairs
- 2005
- address stairs at front stoop risers greater than 3/8 difference
- address garage stairs risers greater than 3/8 difference
- 2nd bathrooms outlets not working
- fill egress window well to drain

Comments: