CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213681 Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Michael Harkins	Partial	Friday, September 02, 2022
Informational:			
1 Misc	-SEAL THROUGH PENETRA AT FIRST FLOOR SHAFT W	TIONS AT CORRIDORS WITH	APPROVED METHODS
Corrective Action Required: 2 THIRD FLOOR	AREA "A" -RC CHANNEL AT UNITS AND CORRIDORS -1ST LAYER AT BATHROOM WALLS -SCREW PATTERN AT UNITS AND CORRIDORS AREA "B" -RC CHANNEL AT UNITS AND CORRIDORS -FIRST,SECOND LAYER AT STAIRWELL UNIT SIDE AND BATHROOMS -SCREW PATTERN AT UNITS AND CORRIDORS		
Corrective Action Required: 3 SECOND FLOOR	AREA "C" -RC CHANNEL AT UNITS A -FIRST, SECOND LAYER AT AREA "A" -RC CHANNEL AT UNITS A -FIRST LAYER AT BATHROO -SCREW PATTERN AT UNIT	UNITS AND CORRIDOR	ED

	AREA " B": -RC CHANNEL AT UNITS AND CORRIDORS -FIRST LAYER SCREW PATTERN -SCREW PATTERN AT UNITS AND CORRIDORS APPROVED
Corrective Action Required:	AREA "C": -RC AT UNITS AND CORRIDORS -FIRST, SECOND LAYER AT UNITS AND CORRIDOR
4 FIRST FLOOR	AREA "A"
	-RC CHANNEL AT UNITS AND CORRIDORS
	-FIRST LAYER SCREW PATTERN
	-SCREW PATTERN AT UNITS AND CORRIDORS APPROVED
	AREA "C"
	-RC AT UNITS AND CORRIDORS
	-FIRST LAYER SCREW PATTERN
	- 9/2/22 2ND LAYER SCREW PATTERN UNITS
	149,151,152,153,154,155,156,157,158,, 160 -
	AREA "B"
	RC UNITS 141,143,144,145,146,148,153 PET WASH,
	LOBBY, BICYCLE STORAGE, STORAGE LOCKERS, CORRIDOR
Corrective Action Required:	
5 STAIR TOWER 1	STAIR TOWER "A"
	- RC channel APPROVED -
Corrective Action Required:	
6 STAIR TOWER 2	STAIR TOWER "B"
Corrective Action Required:	
7 STAIR TOWER 3	STAIR TOWER "C"

Comments: