

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220013
Address: 3546 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, September 06, 2022

Corrective Action Required:

1	Misc	SPLASH BLOCKS, MIN 36" DISCHARGE FROM FOUNDATION, WITH SHORTER SPLASH BLOCKS EITHER REPLACE WITH LONGER BLOCKS OR ADD EXTENSIONS TO DOWNSPOUTS TO KICK SPLASH BLOCKS OUT FOR 36" DISCHARGE
---	------	--

Comments: