

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20223245
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Electrical Inspection - Commercial	Michael Harkins	Failed	Tuesday, September 06, 2022

Corrective Action Required:

1	Miscellaneous Correction	ROOM 1A046 OPEN BOX ABOVE CEILING AT ACCESS DOOR & REAR WALL (BACKORDER)
---	--------------------------	--

Comments: