

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215970  
Address: 4544 NE SENECA TER, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Wednesday, September 07, 2022

Corrective Action Required:

1	Misc	-Final grade, sod, downspout and sump pump extension -Complete deck stair guardrail -Protect the rest of the exposed I joists above finished portion of basement. **Fire block the opening along the top of the wall so that fire cannot spread to the rest of the joist system above the finished basement
---	------	--

Comments: