

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220740
Address: 900 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Wednesday, September 07, 2022

Corrective Action Required:

1	Miscellaneous Correction	LABEL CIRCUIT BREAKERS IN SERVICE PANELS PROVIDE APPROVED COVERS FLOOR RECEPTACLES COMPLETE ALL REQUIRED GFCI RECEPTACLES COMPLETE RECEPTACLES THROUGHOUT LAND ALL CONDUCTORS IN A BOX OR LISTED FIXTURE PROVIDE COVER PLATES FOR SWITCHES & RECEPTACLES
---	-----------------------------	---

Comments: