

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213681
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Michael Harkins	Failed	Wednesday, September 07, 2022

Informational:

1 Misc

-Provide address at disconnect and meters
- PANEL H22 HAS TWO METERS LABELED # 157

PANEL H2A
HOUSE,MAINTENANCE,133,135,136,137,138,140,
142,235,236,237,238,239,240,336,338,339,340,341,342,343,

PANEL H22
HOUSE, 135,149,151,152,155,156,157, ?157? 158,160,
252,253,255,257,259,261,263,256,258,260,
,352,354,356,357,358,359,360,361,363,365,367,

Comments: