

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220590  
Address: 520 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer Construction Inspection</b>	John Jackson	Partial	Wednesday, September 07, 2022

Informational:  
1 Misc 09/07/22 Wednesday JMJ ( Complete Construction )  
Contractor connected to the existing 4" sanitary sewer main approximately 60' with 1 clean-out.  
Contractor also ran tracer wire for locate of sanitary sewer line.

**Comments:**