

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215699
Address: 1917 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, September 08, 2022

Corrective Action Required:

1	Misc	-resolve outstanding inspection fee -guardrail required at front porch, 30" or more from grade, measured on a plane 36" horizontal from edge -garage door should be self closing and latching -label dedicated outlets at garage and unfinished space as not GFCI protected -AFCI circuit protection fridge and breakfast breaker -splash blocks, min 36" discharge from foundation -seal all penetrations in siding
---	------	--

Comments: