

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221526
Address: 904 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Failed	Thursday, September 08, 2022

Corrective Action Required:

1	Miscellaneous Correction	ROUGH FRAMING Provide city stamped truss layout Install doors & windows Tighten anchor bolts on HD08 hold downs South East corner solid block sheathing breaks Truss lock screws at girder truss SE corner North side solid block sheathing breaks rear wall
---	--------------------------	--

Comments: