

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214363
Address: 2950 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, September 08, 2022

Corrective Action Required:

1	Misc	-provide permanent address properly illuminated and of contrasting color to background -hardware at rear sliding doors -secure decking -flood lamp at rear of home -open junction box above deck -garage stairs risers greater than 7 3/4" , more than 3/8 difference in risers -remove gas gauge and cap off
---	------	---

Comments: