

*David P. Ainsworth, P.E.*  
*1200 NW Hearn Ave, Blue Springs, MO 64015*  
*Cell Phone: 816-682-2093*  
*Email: dainsworth@chelepis.com*

September 6, 2022  
Mr. Tracy Ferren  
Mill Creek Builders Inc  
21203 W 81<sup>st</sup> Terrace  
Lenexa, KS 66220

Re: 1514 & 1518 SW Heartwood Dr  
Lee's Summit, MO  
Deck Support Post Pier Inspection

Dear Mr. Ferren:

On September 6, 2022, I inspected the piers that had been prepared for the deck support posts at the above referenced properties.

The piers are about 24" diameter and the base of the piers is about 3' below the final finish grade.

The piers for the deck support posts are approved for concrete placement.

Cordially,



David P. Ainsworth, P.E.

