

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215840
Address: 1928 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Friday, September 09, 2022

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">-resolve outstanding inspection fees-GFCI protection required at tv outlet covered deck-complete electrical for jacuzzi tub, electrical wild in tub cavity-provide handrail bottom flight basement stairs-provide deadbolt at basement walkout-provide security screws basement walkout-interconnection required of all smokes-uncover water meter lid-nail off joist hangers at deck-paint gas line stubs at rear and side of lot-Sump pump discharge min 36" from foundation
---	------	--

Comments: