

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20220445
Address: 900 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	Eric Sharp	Partial	Friday, September 09, 2022

Informational:

1 Misc

No erosion issues to report on the job site today. RP 3-23-22

Informational:

2 Misc

Another rain day, still no erosion issues to report. RP 3-24-22

Informational:

3 Misc

No noted erosion issues. 7/11/22 ES

Informational:

4 Misc

Rain day, no major erosion issues noted. 7/25/22 ES

Erosion control measures installed around perimeter of project. No major issues or concerns. 8/1/22 ES

Erosion control measures installed around perimeter of project. ESS also installed fresh straw wattles along back edge of new sidewalk after backfilling down Black Twig Cir. 8/8/22 ES
Also spoke with Codi about putting blocks behind gutter buddies at inlet boxes. 8/8/22 ES

Erosion control measures installed around perimeter of project. Still need to get blocks in behind gutter buddies at curb inlets down Black Twig Cir. 8/22/22 ES

Erosion control measures installed around perimeter of project. Still in need of blocks behind gutter buddies at curb inlets. Will remind Codi. 9/8/22 ES

Codi put cinder blocks behind gutter buddies along western edge of Black Twig Dr. 9/9/22 ES

Comments: