

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20213681  
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Michael Harkins	Failed	Friday, September 09, 2022

Corrective Action Required:

1 FIRST FLOOR

THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS

AREA C

UNITS AND CORRIDORS APPROVED EXCEPT AS NOTED  
-Correct penetrations in shaft wall

AREA B -COMPLETE

Corrective Action Required:

2 SECOND FLOOR

THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS

AREA "B" UNITS AND CORRIDORS

AREA "C" UNITS AND CORRIDORS

Corrective Action Required:

3 THIRD FLOOR

THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS

AREA "B" UNITS AND CORRIDORS

AREA "C" UNITS AND CORRIDORS

Corrective Action Required:

4            STAIR TOWER 1      STAIR TOWER "A"  
-OK

Corrective Action Required:

5            STAIR TOWER 2      STAIR TOWER "B"  
ALL ROUGH APPROVED

Corrective Action Required:

6            STAIR TOWER 3      STAIR TOWER "C"  
ALL ROUGH APPROVED

Corrective Action Required:

7            STAIR TOWER 4      STAIR TOWER "D"  
PROVIDE H2.5S OR TRUSS LOK SCREWS @ EXTERIOR WALL

**Comments:**