

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20215573
Address: 421 NW KAYLEA CT, LEES SUMMIT, MO 64081
Inspected On: Monday, September 12, 2022
Inspected By: Michael Harkins
Expiration Date: 10/12/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| Inspection: | Inspector: | Outcome: | Date: |
|---|-----------------|------------------|----------------------------------|
| Occupancy Inspection - Codes Residential | Michael Harkins | Temporary C of O | Monday, September 12, 2022 |

Corrective Action Required:

| | | |
|---|-----------------------------|---|
| 1 | Miscellaneous Correction | Sidewalk inspection pending Provide final grade & sod Provide splash blocks Sump shall discharge 36" from foundation Find Manhole cover near ADA ramp |
|---|-----------------------------|---|