

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211027
Address: 2346 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Not Ready	Monday, September 12, 2022

Corrective Action Required:

1	Misc	TCO EXPIRED! SUBMIT TCO EXTENSION FORM AND PAY FEES BEFORE FURTHER INSPETIONS
---	------	--

TCO UNTIL 04/01/22

- pay fees
- address siding from ground at rear of home
- deck post to beam connections requires (2) 1/2" through bolts

Comments: