

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20204934
Address: 1440 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-----------------------------------|--------------|----------|----------------------------|
| Pavement-Curb Construction | John Jackson | Partial | Monday, September 12, 2022 |

Informational:

| | | |
|---|------|---|
| 1 | Misc | 09/12/22 Monday JMJ (Charlie's Concrete Const. / General contractor Star Development) Contractor has installed 80% of curbs without the knowledge of inspector. No proof roll was performed on rock subgrade. I talked with Charlie Ellebracht-Charlie's Concrete an informed him that proof rolls were required as well as third party inspection. Contractor continues to install curbs. |
|---|------|---|

Comments: